

Our Ref: HL/M5557

12 March 2009

WRAS[®]

Water Regulations Advisory Scheme

ICO UK Ltd.
Sandars Road,
Heapham Road Industrial Estate,
Gainsborough,
Lincolnshire,
DN21 1RZ

Dear Sir

WATER REGULATIONS ADVISORY SCHEME "ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

POLYETHYLENE – MATERIAL ONLY

5245

Icorene 1613 DW Blue 5705. Blue coloured polyethylene material. For use with hot and cold water up to 85°C.

Test Report: M 104252

0807507


ICO UK LTD.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Material" or "WRAS - Approved Material". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in July 2013.

Yours faithfully



Anthony Williams
Materials Approval
Water Regulations Advisory Scheme